



**PT. DAIKIN APPLIED SOLUTIONS INDONESIA**  
( Formerly PT. Tatasolusi Pratama )

# Understanding "Heat Load & Psychometric"

by Djunaidi HS





**Welcome  
To The  
Heat Load Calculation  
Course**

What is the heat load? ⇒ It refers to the cooling and heating loads.

What is the heat load calculation? ⇒ It is the calculation of the cooling and heating loads.

Usually software is used to do the calculations.

The calculation results are used to determine the capacity of air conditioners.



# Understanding Of Heat Load (Human Comfort)


# 1) Heat Load

- Classified into 2 main types :

**1. Sensible Heat**

**2. Latent Heat**


# Sensible Heat



(No change in physical state)

# Latent Heat

No change in temperature



**(Physical state is changed)**

## 1.2) Classification of Cooling Loads


- 1) Skin Loads**
- 2) Internal Loads**
- 3) Other Loads**



# 1) Skin Loads


**Skin loads originate from the heat sources outside or external to the conditioned space**

## a) Solar Gain Through glass (SG).




Solar heat gain is reduced by the use of internal or external shading devices such as overhang.

## b) Solar & Transmission Gain Thru Walls and Roofs.




Absorbed Solar Energy (S)  
Transmission (T)


# c) Transmission Thru Glass, Ceiling, Partitions or Floors.



## d) Infiltration.




## e) Ventilation (O.A)



# Skin Loads


- a) **Solar Gain Through glass (SG).**
- b) **Solar and Transmission Gain Through Walls and Roofs.**
- c) **Transmission Through Glass, Ceiling, Partitions or Floors.**
- d) **Infiltration.**
- e) **Ventilation (O.A)**

## 2) Internal Loads




### a) Lighting Loads

### b) People Loads



### c) Equipment Loads





## Room Loads

- Add all sensible loads together results in sensible heat gain.
- Add all latent load together results in latent heat gain.




**Sum of the Room Sensible Heat  
and the Room Latent Heat  
Is the Room Total Heat**

## 3) Other Loads


a. Supply Air Side

b. Return Air Side


c. Outside or Ventilation Air




# Airside Loop



# Supply Fan and Filter



# Cooling Coil




# Cooling Load Components

1. Radiation


2. Conduction

3. Convection



# Cooling Load Components

cooling load components	sensible load	latent load	space load	coil load
conduction through roof, walls, windows, and skylights	✓		✓	✓
solar radiation through windows, skylights	✓		✓	✓
conduction through ceiling, interior partition walls, and floor	✓		✓	✓
people	✓	✓	✓	✓
lights	✓		✓	✓
equipment/appliances	✓	✓	✓	✓
infiltration	✓	✓	✓	✓
ventilation	✓	✓		✓
system heat gains	✓			✓



# WHY Heat Load Calculation? Cooling Load Estimation



## Recommended IAQ (SS 554:2009)

By law, the indoor conditions of an air con space shall maintained within the following limits :

<b>Design Temp.</b>	<b>:</b>	<b>25°C +/- 1 °C</b>
<b>Relative Humidity</b>	<b>:</b>	<b>&lt; 65%</b> (for new buildings) <b>&lt; 70%</b> (for existing buildings)
<b>Air movement</b>	<b>:</b>	<b>0.10 ~ 0.30 m/s</b>

**Note : At occupant level of 1.5m above floor.**

## Heat Transfer Coefficient (U-value)

**Defined as the quantity of heat transmitted under steady state conditions through unit area of the material of unit time when the temperature difference exists between it opposite surfaces.**

**(W/m<sup>2</sup> °C)**

## Calculation of U- value

(Coefficient of heat transmission of wall structure)

$$1/U = 1 / \alpha_0 + l_1 / \lambda_1 + l_2 / \lambda_2 + \dots + l_n / \lambda_n + R + 1 / \alpha_1$$

$\alpha_0$  : External surface heat transfer coefficient [23] [W/m<sup>2</sup> °C]


$\alpha_1$  : Internal surface heat transfer coefficient [9] [W/m<sup>2</sup> °C]

$l$  : Thickness of material [m]

$\lambda$  : Coefficient of thermal conductivity of material [W/m °C]

$R$  : Thermal resistance of air layer [m<sup>2</sup> °C/W]

## Exercise : Calculate U value of outside wall



**Table 4-11 External surface heat transfer coefficient,  $\alpha_o$  [ $W/m^2 \cdot ^\circ C$ ]**

Location of surface	Summertime	Wintertime
Rectangular exterior wall surface	17	23
Rooftop surface	23	35
Planceer	17	17

**Table 4-12 Internal surface heat transfer coefficient,  $\alpha_i$  [ $W/m^2 \cdot ^\circ C$ ]**

Location of surface	Direction of heat flow	
	Upward	Downward
Horizontal	9.26	6.13
Inclined	9.08	7.49
Vertical	Horizontal	8.29

**Table 4-13 Coefficient of Thermal Conductivity of Materials,  $\lambda$  [W/m<sup>2</sup>·°C]**

Name of material	Coefficient of thermal conductivity $\lambda$ [W/m <sup>2</sup> ·°C]	Name of material [W/m·°C]	Coefficient of thermal conductivity $\lambda$ [W/m <sup>2</sup> ·°C]
Air (static)	0.022	Plaster and the like	0.11
Water (static)	0.6	Moisture-proof paper and the like	0.21
Ice	2.2	Tatami mat	0.15
Snow	0.06	Composite tatami mat	0.07
Steel	45	Carpet and the like	0.08
Aluminum	210	Wood (heavy-weight)	0.19
Copper	390	Wood (medium-weight)	0.17
Rock (heavy-weight)	3.10	Wood (light-weight)	0.14
Rock (light-weight)	1.40	Plywood	0.19
Soil (argilliferous)	1.50	Soft fiber board	0.056
Soil (arenaceous)	0.90	Semi-soft fiber board	0.14
Gravel	0.62	Hard fiber board	0.22

PC concrete	1.50	Particle board	0.17
Plain concrete	1.40	Wood wool cement board	0.19
Light-weight concrete	0.78	Glass wool (24K)	0.042
Autoclaved lightweight concrete (ALC)	0.17	Glass wool (32K)	0.040
Concrete block (heavy-weight)	1.10	Rock wool heat insulating material	0.042
Concrete block (light-weight)	0.53	Sprayed rock wool	0.051
Mortal	1.50	Rock wool acoustic board	0.064
Asbestos slate	1.20	Polystyrene foam board (bead)	0.047
Plaster	0.79	Polystyrene foam board (extruded)	0.037
Plaster board / Lath board	0.17	Polystyrene foam board (Freon molded)	0.026
Grout	0.74	Rigid urethane foam board	0.028
Mud wall	0.69	Soft urethane foam board	0.050
Glass	0.78	Polyethylene foam board	0.044
Tile	1.30	Rigid PVC foam board	0.036
Brick wall	0.64	Airtight hollow layer, $R = 0.15 \text{ m}^2 \cdot \text{C/W}$	
Roofing tile	1.00	Non- airtight hollow layer, $R = 0.07 \text{ m}^2 \cdot \text{C/W}$	
Synthetic resin / Linoleum	0.19		
FRP	0.26		

**Answer :**

$$\frac{1}{U} = \frac{1}{23} + \frac{0.005}{1.3} + \frac{0.015}{1.5} + \frac{0.15}{1.4} + \frac{0.015}{1.5} + \frac{0.003}{0.79} + \frac{1}{9} = 0.289$$

$$U = 3.46 \text{ W/m}^2 \text{ } ^\circ\text{C}$$



# Introduction



**Heat Load  
Software**



# Heat Load Calculation HKGSG

## Shortcut

### Project Outline

Project Name

ABC

City/Country

Jakarta/Indonesia

City/Country

Map

Address

123Jakrta

#### Outer Wall Assemblies

- Nomal Concrete
- ALC Plate
- Metallic Curtain Wall
- Wooden construction
- Others

Init value of overall heat trans coeff of main part

Roof(with Ceiling Board) : 1.66 W/m<sup>2</sup>K

Outer Wall : 2.72 W/m<sup>2</sup>K

Inner Wall : 2.62 W/m<sup>2</sup>K

OK

Cancel

Design Data

# Change Design Data(Overall Heat Transfer Coeff)



Outer Wall Ass'y

	Coeff (W/m2K)	Wall Type <input type="text" value="Wall Type:Help?"/>
Outer Wall	<input type="text" value="2.45"/>	<input type="text" value="S"/> <input type="text" value="I"/> <input type="text" value="II"/> <input type="text" value="III"/> <input type="text" value="IV"/>
Inner Wall	<input type="text" value="2.62"/>	
Roof(with Ceiling Board)	<input type="text" value="1.66"/>	<input type="text" value="S"/> <input type="text" value="I"/> <input type="text" value="II"/> <input type="text" value="III"/> <input type="text" value="IV"/>
Roof(without Ceiling Board)	<input type="text" value="2.16"/>	<input type="text" value="S"/> <input type="text" value="I"/> <input type="text" value="II"/> <input type="text" value="III"/> <input type="text" value="IV"/>
Ceiling(with Board)	<input type="text" value="1.95"/>	
Ceiling(without Board)	<input type="text" value="2.69"/>	
Mezz Floor(with Air Layer)	<input type="text" value="1.49"/>	
Mezz Floor(without Air Layer)	<input type="text" value="2.69"/>	
Pilotis	<input type="text" value="3.29"/>	
Earth Floor	<input type="text" value="0.90"/>	

Basement

Undergrnd Wall(D<=2.4m)	<input type="text" value="1.56"/>	W/mK
ID<=2.4m,input Coeff of Heat Transfer / unit length		
Undergrnd Wall(D>2.4m)	<input type="text" value="0.45"/>	W/m2K
Undergrnd Earth Floor	<input type="text" value="0.28"/>	W/m2K

## Design Temp & Humid



Temp in Summer  (CDB)

Humid in Summer  (%RH)

Temp in Winter  (CDB)

Humid in Winter  (%RH)

OK

Cancel

Initial Value

# Room spec



No.  Room Name  Floor  Qty  System

Usage of Room  
 Office  Shop  Hotel  Hospital  Factory  Condominium  Detached  Meeting

Ventilation System  
 Natural  Vent Fan  Total Heat Exc

Ceiling Board  
 Avail  No

Floor Area  m2  
 Ceiling Height  m

Roof&Non-Cond.Ceiling Area(m2)

Upper Room	<input type="text" value="0.0"/>
Flat Roof	<input type="text" value="0.0"/>
Inclined Roof	<input type="text" value="0.0"/>
Glass	<input type="text" value="0.0"/>

Non-Conditioned Floor Area(m2)

Earth Floor	<input type="text" value="0.0"/>
Air Layer Exist	<input type="text" value="0.0"/>
Air Layer No	<input type="text" value="0.0"/>
Pilotis	<input type="text" value="0.0"/>

Equipments

Sensible Heat  W  
 Latent Heat  W

	N	E	S	W	NE	SE	SW	NW	Shade
Outer Wall Length(m)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Window area on Outer Wall(m2)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Inner Wall Length for Non-Cond. Space(m)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

Change Std Data

<input type="button" value="O.H.T.C."/>	<input type="button" value="Temp&amp;Humid"/>	<input type="button" value="Schedule"/>	<input type="button" value="Others"/>	<input type="button" value="Canopy"/>	<input type="button" value="Material II"/>	<input type="button" value="Extension"/>
---	---	---	---------------------------------------	---------------------------------------	--	--

Input room name.

Room Name 

Operating Time Zone

 Hr to  Hr

Hour	1	2	3	4	5	6	7	8	9	10	11	12
Lighting	0	0	0	0	0	0	0	100	100	100	100	0
Persons	0	0	0	0	0	0	0	100	100	100	100	0
Equipments	0	0	0	0	0	0	0	100	100	100	100	100

Hour	13	14	15	16	17	18	19	20	21	22	23	24
Lighting	100	100	100	100	100	100	0	0	0	0	0	0
Persons	100	100	100	100	100	100	0	0	0	0	0	0
Equipments	100	100	100	100	100	100	0	0	0	0	0	0



Room Name

Fresh Air Intake

m3/h person     m3/h

	Air Volume		Ttl Heat Exch Effic	
Summer	<input type="text" value="20.0"/>	m3/h person	<input type="text" value="0.0"/>	%
Winter	<input type="text" value="20.0"/>	m3/h person	<input type="text" value="0.0"/>	%

Internal Heat Gain in Heating

consideration     No consideration

Persons	<input type="text" value="50"/>	%
Lighting	<input type="text" value="50"/>	%
Equipments	<input type="text" value="50"/>	%

Infiltration

Summer	<input type="text" value="0.20"/>	Times/h
Winter	<input type="text" value="0.30"/>	Times/h

Safety Factor

Cooling	<input type="text" value="1.05"/>
Heating	<input type="text" value="1.10"/>

Window Type

Blind Type

Shading Factor: 0.56    O.H.T.C.: 4.97

Humid Method

Total heat load in heating is not contained LH.

Lighting

W/m2     W/Room

Fluorescent Lamp	<input type="text" value="20.0"/>	W/m2
Incandescent Lamp	<input type="text" value="0.0"/>	W/m2

Persons     Underground Wall Depth  m

Height Attic  m






# Input window and Canopy

Please select direction of window with

If there is window without canopy in the same direction, please input zero for canopy dimensions.

Direction	Dc	DI	Dr	Al	Ww	Ar	B	Hw	Hc	Qty
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0

(m)



OK Cancel



# Material II

Room Name

O.H.T.C.(w/m<sup>2</sup>K)

Outer Wall

Inner Wall

Window

Window Type

Blind Type

Shading Factor: 0.63      O.H.T.C.: 4.97

	N	E	S	W	NE	SE	SW	NW	Shade
Outer Wall Length(m)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Window Area on Outer Wall(m <sup>2</sup> )	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Inner Wall Length for Non-Cond.Space(m)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

Room Name

!Detail Set Room Data. Nomally no need to change.

Personnel Heat Gain per Person

Sensible Heat  W/person

Latent Heat  W/person

Glass Surface Ratio(without sash area)

Glass Area = Ttl Window Area \*  !Use for Solar heat gain through

Next Room Condotion

Next room temp diff is calculated using below factor.

$$(dt)=(O/D \text{ Temp}-I/D \text{ Temp}) * \text{Temp Diff Coeff}$$

		N	E	S	W	NE	SE	SW	NW	Ceiling	Floor
Coeff Temp Diff	Cooling	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	Heating	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
Boiler/Kitchen is in Next Room		No	No	No	No	No	No	No	No	No	No

OK

Cancel

Initial Value

## Aircon heat load calculation sheet

Project Name: Kesuma Resort,Bali

Address: Samabe,Bali

13/September/2012

Heat load sum up table

(Upper:W, Lower:kcal/h)

Room name	Fl	Sys-tem	Qty. of rooms	Cooling				Heating				Floor area	Heat load per area	
				Indoor SH	Total	Selected	Time	Total	Selected	Humid.	Time		Cooling	Heating
				[W] (kcal/h)			[Hr]	[W] (kcal/h)		[kg/h]	[Hr]	[m2]	[W/m2] (kcal/hm2)	
Living Room 1	1	1	1	5114 ( 4398)	6744 ( 5800)	7081 ( 6090)	16	7 ( 6)	8 ( 7)	-0.99	6	25.3	279.9 (240.7)	0.3 ( 0.3)
Living Room 2	1	1	1	2590 ( 2227)	3564 ( 3065)	3742 ( 3218)	17	4 ( 3)	4 ( 4)	-0.61	6	16.8	222.8 (191.6)	0.3 ( 0.2)
Entrance	1	1	1	2088 ( 1796)	3053 ( 2626)	3206 ( 2757)	17	4 ( 3)	4 ( 4)	-0.59	6	15.3	209.5 (180.2)	0.3 ( 0.2)
Peak load of building			3	9663 ( 8310)	13260 ( 11404)	13923 ( 11974)	16	15 ( 13)	17 ( 14)	-2.19	6	57.4	242.6 ( 208.6)	0.3 ( 0.2)

SH : Sensible heat

Table of system heat load

(Upper:W, Lower:kcal/h)

Sys -tem	Cooling							Heating						
	Time	F/A vol	Indoor SH	Indoor	Outside	Total	Selected	Time	F/A vol	Indoor	Outside	Total	Selected	Humid.
	[Hr]	[m3/h]		[W]	(kcal/h)			[Hr]	[m3/h]	[W]	(kcal/h)			[kg/h]
1	16	220	9663 ( 8310)	10968 ( 9432)	2292 ( 1971)	13260 ( 11404)	13923 ( 11974)	6	220	0 ( 0)	15 ( 13)	15 ( 13)	17 ( 14)	-2.19

If total indoor heat load is negative, it is not calculated.

F/A : Fresh air

SH : Sensible heat

System table

System	Room name	Floor	Rooms
1	Living Room 1	1	1
1	Living Room 2	1	1
1	Entrance	1	1

System	Room name	Floor	Rooms
--------	-----------	-------	-------

## Room data(Input data)

Project name	Kusuma Resort,Bali									Design room temperature in summer(CDB)	26.0															
Address	Sanabé,Bali									Design room humidity in summer(488)	50.0															
City	Desa Padang/Indonesia									Design room temperature in winter(CDB)	22.0															
Outer wall assembly	Normal Concrete									Design room humidity in winter(488)	50.0															
Max. fresh air temp. in summer(C)	31.0									Fresh air intake	Air volume(m <sup>3</sup> /h/person)															
Min. fresh air temp. in winter(C)	21.0										Summer	20.0														
Room name	Living Room 1										Winter	20.0														
Floor No	1									infiltration ventilation(Fimes/h)	Summer	0.20														
System No	1										Winter	0.30														
No of rooms	1									Heating load internal heat gain(to ratio of cooling load internal heat gain)(%)	Lighting: 50 Persons: 50 Equipments: 50															
Usage of Room	Hotel									Window type <i>	Heat absorbing fan															
Ceiling board	Available									Blind type	Neutral tinted															
Method of fresh air intake	Common ventilation fan									Shading factor/GWTC	0.56/4.97															
Floor area(m <sup>2</sup> )	25.3									Lighting Fluorescent lamp(W/m <sup>2</sup> )	30.0															
Ceiling height(m)	3.4									Incandescent lamp(W/m <sup>2</sup> )	0.0															
RoofNon-air-conditioned ceiling area(m <sup>2</sup> )	Overhead room, Flat roof			, Inclined roof			, Window glass			No of persons	5															
	0.0			0.0			25.3			0.0																
Non-air-conditioned floor area(m <sup>2</sup> )	Earth floor		, with air layer,		Without air layer,		Pilotis			Depth of underground wall(m)	0.0															
	0.0		5.4		0.0		0.0			Underground wall is valid only when outer wall is negative value.																
Outer wall length(m) <i>	N	E	S	W	NE	SE	SW	NW	Shade	Height above attic(m)	0.6															
	0.0	0.0	0.0	0.0	0.0	4.4	5.5	0.0	0.0	Humidifying method	Without humidifier															
Window area on outer wall(m <sup>2</sup> )	0.0	0.0	0.0	0.0	0.0	0.4	0.7	0.0	0.0	Overall heat transfer coefficient	(W/m <sup>2</sup> K)															
Non-conditioned inner wall length(m)	0.0	0.0	0.0	0.0	0.0	3.7	5.5	0.0	0.0	Outer wall	<i>															
	Outer wall length with negative value is regarded as underground wall.										Inner Wall	<i>														
Cooling load heat gain from equipments(W)	Sensible heat,		Latent heat									Roof(with ceiling board)	1.66													
	500		0									Ceiling(with ceiling board)	1.95													
Operating time zone	4:00 to 24:00											Mezz floor(with air layer)	1.49													
Internal heatgaining schedule(%)	Time	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	Mezz floor(without air layer)	3.69		
	Lighting	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	Pilotis	3.39	
	Persons	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	Earth floor	0.90	
	Equipments	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	Underground wall(depth<=2.4m)	1.56 (W/mK)	
																								Underground wall(depth>2.4m)	0.45	
																								Safety factor	Cooling	1.05
																								Heating	1.10	



Table of room heat load

Room name	Floor	System	Rooms	Usage	F1 area(m2)	Height(m)	No of person	F/A volume(m3/h)
Living Room 1	1	1	1	Hotel	25.3	3.6	5	Summer 100.0/Winter 100.0

[Cooling load] Condition of indoor design temperature & humidity: 26.0(CDB) 50.0(WRH) [W] (kcal/h)

Time	F/A cond.		Outer Wall	Roof & Ceiling	Inner Wall	Floor	Window	Infiltration		Human body		Light -ing	Equipments		Indoor heat		Fresh air	Total heat load
	CDB	WRH						SH	LH	SH	LH		SH	LH	SH	LH		
4	27.1	88.8	45	23	34	4	94	7	147	295	430	880	500	0	1882	577	845	3304( 2841)
5	27.0	89.3	35	18	31	3	85	6	147	295	430	880	500	0	1853	577	842	3272( 2814)
6	27.0	89.3	35	18	31	3	85	6	147	295	430	880	500	0	1853	577	842	3272( 2814)
7	27.2	88.7	38	14	37	4	1125	7	149	295	430	880	500	0	2890	579	857	4326( 3720)
8	27.7	86.6	40	14	52	6	1521	10	150	295	430	880	500	0	3318	580	882	4780( 4111)
9	28.5	83.4	86	28	77	8	1688	15	153	295	430	880	500	0	3577	583	925	5085( 4373)
10	29.4	79.6	154	74	106	11	1957	20	155	295	430	880	500	0	3597	585	962	5144( 4424)
11	30.4	75.8	238	148	136	15	1902	26	158	295	430	880	500	0	3730	588	1012	5330( 4584)
12	31.1	72.8	384	259	158	17	1625	31	158	295	430	880	500	0	4069	588	1035	5692( 4895)
13	31.7	70.4	368	393	176	19	1657	34	158	295	430	880	500	0	4322	588	1055	5965( 5130)
14	31.8	70.0	425	541	179	19	1635	35	158	295	430	880	500	0	4509	588	1058	6158( 5293)
15	31.7	70.4	471	670	176	19	1843	34	158	295	430	880	500	0	4888	588	1055	6531( 5617)
*16	31.3	72.0	567	753	164	18	1965	32	158	295	430	880	500	0	5114	588	1042	6744( 5800)
17	30.6	75.0	542	781	142	15	1726	28	158	295	430	880	500	0	4909	588	1019	6516( 5604)
18	29.9	77.7	559	748	121	13	927	23	156	295	430	880	500	0	4066	586	988	5640( 4850)
19	29.1	80.9	549	656	96	10	243	19	155	295	430	880	500	0	3268	585	952	4869( 4132)
20	28.5	83.4	495	527	77	8	212	15	153	295	430	880	500	0	3069	583	925	4517( 3885)
21	28.1	85.0	415	388	65	7	179	13	152	295	430	880	500	0	2742	582	903	4227( 3635)
22	27.8	86.1	325	263	55	6	153	11	150	295	430	880	500	0	2488	580	885	3853( 3400)
23	27.6	87.1	239	162	49	5	136	10	150	295	430	880	500	0	2276	580	879	3735( 3212)
24	27.4	87.7	167	92	43	5	119	8	149	295	430	880	500	0	2109	579	863	3551( 3054)

F/A : Fresh air  
SH : Sensible heat  
LH : Latent heat

[Heating load] Condition of indoor design temperature &amp; humidity: 22.0(CDB) 50.0(WRH)

[W] (kcal/h)

Time	F/A cond.		Outer Wall	Roof & Ceiling	Inner Wall	Floor	Window	Infiltration		Human body		Light -ing	Equipments		Indoor heat		Fresh air	Total heat load
	CDB	WRH						SH	LH	SH	LH		SH	LH	SH	LH		
4	22.2	83.9	0	268	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
5	22.0	84.3	0	277	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
6	21.8	85.4	15	286	6	1	19	2	0	-148	0	-440	-250	-0	0	0	7	7( 6)
7	22.0	84.3	0	277	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
8	22.6	82.4	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
9	23.4	79.6	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
10	24.4	76.5	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
11	25.4	73.0	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
12	26.3	70.1	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
13	26.8	68.5	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
14	27.0	67.7	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
15	26.9	68.1	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
16	26.7	69.0	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
17	26.4	69.7	0	0	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
18	25.9	71.4	0	97	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
19	25.3	73.5	0	125	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
20	24.8	75.2	0	148	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
21	24.4	76.5	0	166	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
22	24.0	77.8	0	185	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
23	23.6	79.2	0	203	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)
24	23.2	80.6	0	222	0	0	0	0	0	-148	0	-440	-250	-0	0	0	0	0( 0)

Total heat load in heating is not contained latent heat.If total indoor heat load is negative,it is not calculated.

F/A : Fresh air  
SH : Sensible heat  
LH : Latent heat


Heat load graph

Room name	Floor	System	Rooms	Usage	F1 area(m2)	Height (m)	No of person
Living Room 1	1	1	1	Hotel	25.3	3.6	5

Indoor

Summer 26.0C 50.0%

Winter 22.0C 50.0%





Outdoor

Summer 31.3C 72.0%

Winter 21.6C 85.4%

Fresh air Vol. Summer:100.0m3/h Winter:100.0m3/h



[Detail]

(W)	Time	Outer wall	Roof & Ceiling	Inner wall	Floor	Window	Infiltration		Human body		Light-ing	Equipments		Fresh air	Total heat load	Selected heat load
							SH	LH	SH	LH		SH	LH			
Summer	16	507	753	164	18	1965	32	158	295	430	880	500	0	1042	6744	7081
Winter	6	15	286	6	1	19	2	0	-148	0	-440	-250	-0	7	7	8


Note) Total indoor heat load & selected heat load are not contained latent heat.If total indoor heat load is negative, it is not calculated.  
 SH : Sensible heat  
 LH : Latent heat

**Any Question ?**

# Psychometric Chart

## How to use the Psychometric Chart


- - Mixture of Air -



# Introduction

## ◆ The psychrometric chart allows for:

- Instant understanding of air properties;
- Display of change of the state of the air;
- Display of the air conditioning process.



# Contents

1. What the composes the Psychometric Chart
2. Mixture of Air
3. Summary

Air conditioners conduct various processes including mixing, cooling, heating, dehumidifying and humidifying of air.

Let's use a psychrometric chart to think about mixture of air.






# 1. What Compose the Psychrometric Chart

Psychrometric chart

You can read seven properties of air on the chart.



## 1. Change Air State

# *Changes in Air State*

- *Heating*
- *Cooling*
- *Cooling/Dehumidification*
- *Humidification*



Air conditioners conduct various processes including mixing, cooling, heating, dehumidifying and humidifying of air.

Let's use a psychrometric chart to think about mixture of air.





# Summary Chart

Heating	Humidification	Cooling	Cooling/Dehumidification
---------	----------------	---------	--------------------------



# Summary Chart



Amount of cooling generated by the coil

$$10.27 \times \frac{1,000}{0.87} = 11,805 \text{ kJ/min}$$



$$= 197 \text{ kJ/s}$$

$$= 197 \text{ kW}$$

Dew point temperature of the coil inlet air is 16.6°C

# Summary Chart

Heating	Humidification	Cooling	Cooling/Dehumidification
---------	----------------	---------	--------------------------




# Summary Chart

Heating

Humidification

Cooling

Cooling/Dehumidification



Amount of cooling by the coil


$$14.13 \times \frac{1,000}{0.87} = 16,241 \text{ kJ/min}$$

$$= 271 \text{ kJ/s} = 271 \text{ kW}$$


Amount of dehumidification by the coil

$$0.0015 \cdot \frac{1,000}{0.87} = 1.72 \text{ kg/min}$$

Dew point temperature of the coil inlet air is 16.6°C




# Summary Chart



SHF (Sensible Heat Factor)

$$= \frac{\text{Sensible heat}}{\text{Total heat}} = \frac{10.24}{14.13} = 0.725$$



## **3 Method of Cooling Load**

- 1. Heat Load Calculation**
- 2. ACH (Air Change per Hour)**
- 3. Assuming method..... Ex  $1 \text{ m}^2 = 700 \text{ btu/h}$**


### **Calculate Heat Load with ACH**

- Room Dimension (L x W x H) =  $13 \times 10 \times 6 = 780 \text{ m}^3$**
- Ambient Temperature =  $30 \text{ }^\circ\text{C}$ , RH = 79%**
- Target Room Condition =  $24 \text{ }^\circ\text{C}$ , RH = 50%**
- ACH = 15 kali**
- Fresh Air Assume 10%**



## ***DETERMINE ?????***

- 1. Airflow = 15 ACH x 780 m<sup>3</sup> = 11700 CMH  
6886 CFM**
- 2. Fresh Air = 10% x Airflow = 1170 CMH  
688.6 CFM**
- 3. Mixing Air (T<sub>ma</sub>) = 25.5<sup>o</sup>C, RH = 59.5%**
- 4. Leaving Air Condition      T<sub>LA</sub> = 12<sup>o</sup>C  
RH = 93%**



# Calculate Cooling Load

- $Q_{\text{sensible}} = 4,5 \times \text{CFM} \times (h_x - h_{la})$   
183,753 Btu/h or 53.85 kW or 15.31 TR
- $Q_{\text{Latent}} = 4,5 \times \text{CFM} \times (h_{\text{mix}} - h_x)$   
137,582 Btu/h or 40.32 kW or 11.47 TR
- $Q_{\text{Total}} = 4,5 \times \text{CFM} \times (h_{\text{mix}} - h_{la})$   
321,335 Btu/h or 94.17 kW or 26.7 TR
- Sensible Heat Ratio = 0.572**
- Air Condition After Reheat = 20.3°C RH =55%**
- $Q_{\text{Reheat}} = 4,5 \times \text{CFM} \times (h_{la2} - h_{la})$   
114.032 Btu/h or 33.42 kW

# Conclusion

1. Cooling Capacity = 94.2 kW
2. Capacity Reheat = 33.4 kW
3. Airflow = 11700 CMH or 6886 cfm
4. Room is class 100,000 should be complete with Medium and HEPA filter

# Thank You