

# MCQUAY APPLICATION








#### PT. DAIKIN APPLIED SOLUTIONS INDONESIA

(Formerly PT. Tatasolusi Pratama)





#### **Long Piping Design Offers Flexibility**



- \*2 For 5MDS120B(R) and above
- \*3 For OD is above indoor

- Maximum length
   between OD and ID
   (longest branch):
   R410A 175 meters\*2
- The maximum height between OD and the lowest ID is 50 meters\*3
- The maximum height between highest and lowest ID is 15 meters

#### McQuay Air Conditioning

### Modular Digital Scroll & Variable Refrigerant Flow System

Menara Palma Case Study

Menara Palma is one of the iconic tower in Jakarta Selatan. Total build area is around 30,000m² where the whole building are using McQuay MDS System. The building is 26 level height and all the MDS Outdoor Units were allocated on the rooftop & balcony of level 2 –14. This project was supplied by McQuay and finished installed in the year of 2009.

This project are using all Air Cooled MDS System, by using air cooled DX system, the building are free of chilled water matainance. The main building are mostly using ceiling concealed with ducting system, most of the level are rented out to other tenant like Pt. AIA, ZOMATO, PT. BIMA SAKTI BERJANGKA, KORSINDO FOUNDATION, etc. In order to make the tenant more convenience and flexible to use the Air Conditioners, MDS system allowed the individual control & efficient partial load.

This building have been operated since 2010 and until now the MDS system still providing the comfort & cooling air to the building. With this project reference, we believed that MDS is one of the most reliable system which combining the digital scroll technologies with variable refrigerant flow application.





3 198						_		
3 (52)								
E								
8 401	:		- G G				H040 H1040	
B 4500	:		_	-		#134 #134	100 1100 100 1100 100 1100 100 1100	
5 April	į	randrandran		SIL.	*** *** **		TPTW/TPTM	
8		THE THE			MAN 2014 M	THE REAL PROPERTY OF	CH100 00H44	
H 45/H		38 SE		- E	28, 28, 2	a, 55, 5	E' 58	
5 496		740		UNITE		Market Co.		
B				100	an an a		F 850	
* 49*				CIE.	CONT. CONT. CO.	- CE C	E' 5E'	
H 1500			HE COMMENT	Office Call.	COMP COMP COMP	_		
n 45e		HOHER HEING HE	AC REMENT RESERVE	UTURN		-		
8		SERVE SERVE SE			CHI CHI K	- FEET - EE	2 2 E	
8		20 20 CB	CE CE CE	SET.		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	E 181	
11 458			CH CH CH	CIT.	CHI CHI C	_		
17 4628			•	Littler	200 CE C	-		
1 4500				SEP.		-		
					EM EM E	2 KH C	15 ES LA	
11 4000		CH CH	9 9 9	CORT.	CHE CHE C	T CH C		
4 400			•	CE '		E CE C	145	
12 4900			PER	UPLES		_		
8		MAN KAN	CH CH CH		SHE SHE S	H KHU K		
8		Call Call		200	CH CH C	E CE C	5 SE	TTE SILES
11 1/200		SE SE			SE SE S		ger ja	II'Th
N 498			-	Office of Party		-		
				mens.		HO REHIND REH	W EH L	
8					200 200 E	2 Sec. 2	# H	
			THE ST. ST.	CONT.	TH TH T			
, 448				DATE:	या या र	_		
. 490			•	LTLAN		-	L.E.	112
3 4300					CEL CEL C	-	45 KH	
§		32 SE		META CEL.	20 CB C	20 Marie 20	. SE 6	
8		열 열	9 9 9	CIT.	GF GF C			
3 400		CE CE	æ	LITERY		•	L.E.	7Th
1 4m		NAMES OF THE PARTY OF		SE V		_	li S	
2 mars			28 28 C	EST.	Arr Rr.		A 80	
1 640			l <u>a</u>	DELINE THE PERSON NAMED IN				<b>3</b>
u -ym	MIT	***************************************	4	Page 1	G 500 G 500			
az -ym								$\dashv$
R <sub>33</sub> -5m								
	•		a 1	_			_	

Buid up	Area	30,000 m <sup>2</sup>		
bala ap	Height	26 Floor		
	Total Cap.	18,780,000 Btu/hr		
System	Outdoor	84		
	Indoor	465		
	Office	MDS System		
	Parking	MWM		
Application		Centralized Control		
	Control	3 Gate Way		
		3 PC		





Another Quality Product by **DAIKIN** 





**LOBBY AREA MENARA PALMA** 



Another Quality Product by **PAIKIN** 



**ZOMATO RESTAURANT** 





MWCP18 - MWCP205

Capacity (HP) 5.8 - 68



MWH008 – MWH350 Capacity (HP) 0.8 – 32.4

# WATER COOLED PACKAGED





# **Water Cooled Package System**

Mall Bale Kota Case Study





Duidun	Area	188,000 m <sup>2</sup>		
Buid up	Height	4 Floor		
	Total Cap.	56,000,000 Btu/hr		
System	Outdoor	0		
	Pakage	334		
	Shops	MWH		
Application	Common area	MWCP		
	Controll	Individual Controller		

MALL BALE KOTA

JL. SUDIRMAN – TANGERANG – BANTEN

# **Water Cooled Package System**

#### Mall Bale Kota Case Study



Mall Bale Kota is one of the most largest mall located in Tangerang. The build up area is almost 190,000m<sup>2</sup>. This mall positioning them self as the high class commercial area where their tenants included fashion, beauty, health care, reataurant, life style, etc.

Since the tenants are having various type of business & the business operation hours are mostly difference, their requirement of air conditioning usage will also difference. Thus, with installed the McQuay Water Cooled Pakage System, it is much easier for the individual control as well as the tenant management.


All tenant are now using the colling water which connected to the cooling tower for cooling down the condenser on their own unit, this process is centralized control by the mall management.

Mall Bale Kota started operating since year 2012 and until now there are zero complaint received by the customer because of the system liability and of course with the good practice of right installation.



# **Piping Skematik Diagram WCP**















**Tenant Mall Balekota** 





# AIR HANDLING UNIT





# **RSUD Dr. Mohammad Soewandhie**

JL. Tambak Rejo No. 45 – 47, Surabaya

Another Quality Product by **PAIKIN** 

# **Air Handling Unit**





Since the Indonesia economic has been grown rapidly in recent years, the demand of the hospital and its facilities are keep on increased as well. RSUD Dr. Soewandhie is one of the hospital in Surabaya that had improved their facilities to suite the international standard especially for the Operating Theatres. In order to provide the comfort, clean & safety used medical environment for their patients, RSUD Dr. Soewandhie had choosen McQuay AHU system to be installed into their 4 Operating Theatres.

Total build up area is 4,768 m<sup>2</sup>. They are classified as Class B. The OT room have all the McQuay AHU system design was based on ASHREA standard example air change per hour, RH, design temprature & class of filter.



Buid up	Area	4,768m <sup>2</sup>		
вии ир	Class	В		
	Total Cap.	655,000 Btu/hr		
System	Airflow	15,000 CFM		
	Fresh air	15%		
	Design			
	Temp.	22degC		
Application	RH	50%		
	Filter	Primary G4		
	riitei	Secondary F8		

The new OT room were started operating since year 2012 and RSUD Dr. Soewandhie now had obtained the "Akreditasi 5 Pelayanan" from "Komite Akriditasi Rumah Sakit Departemen Kesehatan Republik Indonesia".



Table 3 Ventilation Requirements for Areas Affecting Patient Care in Hospitals and Outpatient Facilities

	Relationship to Adjacent		Total Air Changes per	Exhausted Directly to	Air Recirculated Within Room		
Function Space	Areas <sup>a</sup>	per Hour <sup>b</sup>	$\operatorname{Hour}^{c}$	Outside <sup>m</sup>	Units <sup>d</sup>	%	°C
Surgery and Critical Care							
Operating room (class B and positive C surgical)	Positive	4	20	_	No	30 to 60	17 to 27
Operating/surgical cystoscopic rooms of q	Positive	4	20	_	No	30 to 60	20 to 23 <sup>r</sup>
Delivery room <sup>p</sup>	Positive	4	20	_	No	30 to 60	20 to 23
Recovery room <sup>p</sup>	_*	2	6	_	No	30 to 60	$24 \pm 1$
Critical or intensive care (burn or intermediate)	Positive*	2	6	_	No	30 to 60	21 to 24
Newborn intensive care	Positive*	2 2	6	_	No	30 to 60	22 to 26
Treatment room <sup>5</sup>	*	2	6	_	_	30 to 60	21 to 24
Nursery suite	Positive	5	12	_	No	30 to 60	24 to 27
Trauma room <sup>f, s</sup>	Positive	5	12	_	No	30 to 60	22 to 26
Trauma room (crisis or shock)	_	3	15	_	No	30 to 60	22 to 26
Anesthesia gas storage	Negative	_	8	Yes		_	_
GI endoscopy ab	_	2	6	_	No	30 to 60	20 to 23
Bronchoscopy <sup>q</sup>	Negative	2	12	Yes	No	30 to 60	20 to 23
Emergency waiting rooms	Negative	2	12	Yes	_	30 to 60	22 to 26
Triage areas	Negative	2	12	Yes	_	_	21 to 24
Radiology waiting rooms	Negative	2	12	Yest	_	_	21 to 24
Procedure room (class A surgical)	Positive	3	15	_	No	30 to 60	21 to 24
Nursing							
Patient room	*	2	6 <sup>v</sup>	_	_	30 (W), 50 (S)	21 to 24
Toilet room <sup>8</sup>	Negative	Optional	10	Yes	No	· <u>-</u> · ·	_
Newborn nursery suite	_*	2	6	_	No	30 to 60	22 to 26
Protective environment room <sup>i, q, w</sup>	Positive	2	12	_	No	_	21 to 24
Airborne infection isolation room <sup>h,q, x</sup>	Negative	_	12	Yesu	No	30 to 60	21 to 24
Isolation alcove or anteroom <sup>w, x</sup>	Pos./Neg.	2	10	Yes	No	_	_
Labor/delivery/recovery/postpartum (LDRP)	_*	2	6v	_	_	30 (W), 50 (S)	21 to 24
Public corridor	Negative	2	2	_	_		_
Patient corridor	*	2	4	_	_	_	_

A ..........







# ISMANTO DISTRIBUTION CHAIN

Office: P. +62-21-7919 2468; F. +62-21-7919 2473

Mobile : +62-813 1551 1506


Email: ismanto@daikinapplied.co.id

- Building Overview

Project Name: Technology Park Tangerang
 Design required: Management office building

- 1. Prepare a presentation that you could present to owner, work the design by devide into 6 group, each of you shall contribute in the proposal
- 2. You will be concise and restrict your presentation to 30 Mins and allow an additional 15 Mins for discussion







- Supporting photo of the office

Project Name: Technology Park Tangerang
Design required: Management office building












- Lay out





- Design Load

Project Name: Technology Park Tangerang
 Design required: Management office building

<b>Design Condition:</b>			Criteria for the Owner			
	CDB	R.H. %				
Cooling	35	74%	Building	: 2-Storey Office Block with Slab roof.		
			Floor to Floor height	: 3.5metres		
	Design L	oad (kW)	Floor to Ceiling Height	: 2.7 metres		
First Floor	Total		Metres square/person	: 5 (Office) / 2.5 (Meeting Rm)		
Reception	18.7		Fresh air requirement	: 0.65 l/s per m2 (office)		
Manager	9.7		Fresh air requirement	: 2.8 l/s per m2 (Meeting Rm)		
Meeting Room	9.8		Window thickness	: 8mm		
Lan / Server Room	11.2		Glass Door at 1st Floor	: 8mm		
Open Area Office	34.4		Windows	: Venetian Vertical Blinds		
•			Full Height windows	: North, East and West side		
2 <sup>nd</sup> Floor			Lan / Server room	: Glass with partition wall		
Total 85				(Combo wall 150mm)		
	55		Lan / Server room	: Standby (Wall mounted FCU/Ceiling Expose)		
Design Temperature :	24 deg C; RH = 55%		All area	: Ducted FCU with ducted returned.		
= <b>0</b>			Manager and Mtg Rm	: Cassette / Ducted		

**McQuay** 

- Solutions

**Project Name: Technology Park Tangerang** 

Design required: Management office building



MDS ??



AHU??




MWCP??

Another Quality Product by **PAIKIN** 









Office: P. +62-21-7919 2468; F. +62-21-7919 2473

Mobile : +62-813 1551 1506

Email: ismanto@daikinapplied.co.id

Another Quality Product by **DAIKIN**